

2018 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
17-Jan	37	38	6	5	10.00	2.54
23-May	88	53	12	6	3.20	1.78
15-Aug	6	21	6	9	1.30	3.39
07-Nov	18	40	6	5	2.60	1.78
Average	37	38	8	6		

- Effluent standards are: (as per DELGNB certificate S-2628)

CBOD₅ and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.) - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.