

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted 7:36pm
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted 7:38pm

Step 3	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@df-mpo.gc.ca">Closure-Fermeture@df-mpo.gc.ca</a>	OR	506-851-2615
	Canadian Food Inspection Agency		<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Diane Fury Josée Theriault	<a href="mailto:marc.leger@gnb.ca">marc.leger@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a>	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater  
 Release of Untreated wastewater *diluted*  
 Unplanned discharge  
 Planned discharge

Source of discharge:

Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18

Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: #2, 227 Main Street, Shediac  
 Lift Stations: \_\_\_\_\_

Start of event:  Known  Estimated

Date: May 21, 2019

Time: 7:30pm

Flow: 20 Units: usgpm  Known  Estimated  
 Total volume: \_\_\_\_\_ Units: \_\_\_\_\_  Known  Estimated  
 Fecal coliform: \_\_\_\_\_ MPN/100mL  Known  Estimated

Comments: Caused by heavy rain

Reported by (name): Joey Frenette Position: General Manager

Phone: 506 533 0039 Date: May 22, 2019

**Annex C2 – Notice of **END** of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@dfp-mpo.gc.ca">Closure-Fermeture@dfp-mpo.gc.ca</a>	OR	506-851-2615
	Canadian Food Inspection Agency		<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	<a href="mailto:Marc.Leger@gnb.ca">Marc.Leger@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you the following event has ENDED:**

- |  |   |
|--|---|
| <input type="checkbox"/> Release of Partially-treated wastewater                   | <input checked="" type="checkbox"/> Unplanned discharge |
| <input checked="" type="checkbox"/> Release of Untreated wastewater <i>diluted</i> | <input type="checkbox"/> Planned discharge              |

Comments: LS#2, 227 Main St, Shediac  
Ended 2:30am May 22  
=> 7 hours overflow at ≈ 20 usgpm (diluted overflow)

Reported by (name): Joey Frenette Position: General Manager  
 Phone: 506 533 0039 Date: May 22'19