

2019 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
12-Feb	71	66	6	5	11.00	2.10
22-May	42	67	12	10	3.80	1.52
28-Aug	94	87	6	7	16.00	2.70
06-Nov	54	59	6	5	2.00	1.49
Average	65	70	8	7		

- Effluent standards are: as per DELGNB certificate S-2628 (until April 2019); the CofA S-3169.

CBOD₅ and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.) - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.