

2020 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
12-Feb	145	98	6	5	8.90	2.14
20-May	163	114	13	12	3.30	1.40
Average						

- Effluent standards are: as per DELGNB CofA S-3169.

CBOD₅ and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.) - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.