

**Annex C1 – Notice of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

<b>Step 1</b>	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted 12:30pm
<b>Step 2</b>	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted 12:34pm

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@dfo-mpo.gc.ca">Closure-Fermeture@dfo-mpo.gc.ca</a>	OR	506-851-2615
Canadian Food Inspection Agency			<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	<a href="mailto:marc.leger@gnb.ca">marc.leger@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you of the following event:**

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: #2, 227 Main St, Shediac  
 Lift Stations: \_\_\_\_\_

Start of event:  Known  Estimated

Date: August 18, 2018  
 Time: 12:15pm

Flow: ≈ 20 l/s Units: \_\_\_\_\_  Known  Estimated  
 Total volume: on-going Units: \_\_\_\_\_  Known  Estimated  
 Fecal coliform: — MPN/100mL  Known  Estimated

Comments: due to heavy rain

Reported by (name): Joey Frenette Position: General Manager

Phone: (506) 533-0039 Date: Aug 18 '18

*Joey Frenette*

**Annex C2 – Notice of **END** of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@dfo-mpo.gc.ca">Closure-Fermeture@dfo-mpo.gc.ca</a>	OR	506-851-2615
	Canadian Food Inspection Agency		<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	<a href="mailto:Marc.Leger@gnb.ca">Marc.Leger@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you the following event has ENDED:**

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Comments: LS#2, 227 Main St, Shediac - Diluted wastewater overflow (due to heavy rain) stopped at 4:15pm.

Reported by (name): Joey Frenette Position: General Manager  
 Phone: (506) 533-9648 Date: Aug 18' 18