

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted

Step 3	To:	Name	eMail	OR	Fax
Environment Canada	MWQM Atlantic		shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture		Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB Health NB Health NB	Marc Léger Diane Fury Josée Theriault		marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: No 2 (227 Main St) & No 3 (38 Oak street)
Lift Stations: _____

Start of event: Known Estimated

Date: Jan 24, 2019 *LS#2 & #3*
Time: 11:45pm

Flow: 10 to 20 Units: l/s/gpm Known Estimated
Total volume: _____ Units: _____ Known Estimated
Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Due to Heavy Rain + snow melt.

Reported by (name): Daniel St-Amand Position: Operator

Phone: (506) 532 7025 Date: Jan 25, 2019
Steve Poubelle

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Comments:

LS #2 & LS #3 overflow of diluted wastewater ended at 9:00 am Jan 25'19 (overflows lasted 9 hours 15 min)

Reported by (name):

Daniel St-Amand

Position:

Operator

Phone:

(506) 532-7025

Date:

Jan 25'19

[Signature]