

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted 10:25am
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted 10:30am

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: NO. 2, 227 Main St, Shediac
Lift Stations: _____

Start of event: Known Estimated

Date: 20 April 2019
Time: 9:55 am

Flow: 5 to 10 Units: 1.5 gpm Known Estimated
 Total volume: _____ Units: _____ Known Estimated
 Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Due to heavy rain!

Reported by (name): Gilles LeBlanc Position: Operator

Phone: 506-532-7025 Date: 20 April 2019

Alex Sack

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Comments: Lift station No. 2, 227 Main St, Shediac
diluted overflow ended at 5:00pm, April 20, 2019

Reported by (name): Gilles LeBlanc

Position: Operator

Phone: 506-532-7025

Date: 20 April 2019

Jean Soutte