

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Ismael (Environment)

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted	<i>10:00pm</i>
Step 2	[CMP Notification System (Atlantic Catch Data)] # <i>2019 06092210</i>	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted	<i>Dorine 10:00pm</i>

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater

- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: # 1, 63 Evergreen drive, Shediac
Lift Stations: _____

Start of event: Known Estimated

Date: 9 June 2019
Time: 8:30 pm

Flow: one Units: 105gpm Known Estimated
Total volume: — Units: _____ Known Estimated
Fecal coliform: — MPN/100mL Known Estimated

Comments: Cracked force main - leaking near 56 Boutermin Drive

Reported by (name): Gilles LeBlanc Position: Operator

Phone: 533-0054 Date: 9 June 2019

Alex P... (Signature)

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- | | |
|---|---|
| <input type="checkbox"/> Release of Partially-treated wastewater | <input checked="" type="checkbox"/> Unplanned discharge |
| <input checked="" type="checkbox"/> Release of Untreated wastewater | <input type="checkbox"/> Planned discharge |


LS#1 forcemain leak


Comments: *Ended June 11'19 @ 11:30am*
Estimated total ⇒ 156 minutes of pump "run" time
x ≈ 1 gal/min = total 156 gallons

Reported by (name): *Joey Frenette* Position: *General Manager*
 Phone: *506 533 0039* Date: *June 11'19*

Joey Frenette



 area of forcemain leak.

 forcemain / pipe