

**Annex C1 – Notice of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

<b>Step 1</b>	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted 6:16pm
<b>Step 2</b>	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted 6:19pm

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@dfo-mpo.gc.ca">Closure-Fermeture@dfo-mpo.gc.ca</a>	OR	506-851-2615
Canadian Food Inspection Agency			<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	<a href="mailto:marc.leger@gnb.ca">marc.leger@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you of the following event:**

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Release of diluted untreated wastewater
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: # 2, 227 Main St, Shediac, NB  
Lift Stations: \_\_\_\_\_

Start of event:  Known  Estimated

Date: July 5'19

Time: 5:40pm

Flow: ≈ 20 to 30 usgpm Units: \_\_\_\_\_  Known  Estimated  
 Total volume: \_\_\_\_\_ Units: \_\_\_\_\_  Known  Estimated  
 Fecal coliform: \_\_\_\_\_ MPN/100mL  Known  Estimated

Comments: due to heavy rain / flash rain / thunderstorm

Reported by (name): Joey Frnette Position: General Manager  
 Phone: 506 532 7025 Date: July 5'19

*Joey Frnette*

**Annex C2 – Notice of **END** of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@dfm-mpo.gc.ca">Closure-Fermeture@dfm-mpo.gc.ca</a>	OR	506-851-2615
	Canadian Food Inspection Agency		<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	<a href="mailto:Marc.Leger@gnb.ca">Marc.Leger@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you the following event has ENDED:**

- Release of Partially-treated wastewater
- Unplanned discharge
- Release of Untreated wastewater
- Planned discharge
- Release of diluted untreated wastewater

Comments: Lift station #2 227 Main St, Shediac  
Ended 7:50pm.  
Duration: 2 hours 10 min => between 2,600 usgpm & 3,900 usgpm

Reported by (name): Joey Frenette Position: General manager  
 Phone: 506 532 7025 Date: July 5'19

*Joey Frenette*