

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted

2019 08 10 16 38

Step 3	To:	Name	eMail	OR	Fax
Environment Canada	MWQM Atlantic		shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture		Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB Health NB Health NB	Marc Léger Diane Fury Josée Theriault		marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater *Rain event*
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

3:45pm start
7:50pm stop
start at 4:05pm
stop 9:15pm
start at 4:18pm
stop 11pm

Lift Stations: 4, 2, 3

Lift Stations: _____

Start of event: Known Estimated

Date: 10 Aug 2019

Time: 3:45 pm

Flow: 5 to 10 Units: US gal/min Known Estimated

Total volume: _____ Units: _____ Known Estimated

Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Rain Event and Town Storm sewer Plugged over 6" of water on Streets Downtown

Reported by (name): Gilles Bellane Position: Operator

Phone: 506 533-0054 Date: 10 Aug 2019

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- | | |
|--|---|
| <input type="checkbox"/> Release of Partially-treated wastewater | <input checked="" type="checkbox"/> Unplanned discharge |
| <input type="checkbox"/> Release of Untreated wastewater | <input type="checkbox"/> Planned discharge |

Comments: Rain Event, Over 6" of rain fell
Town Storm plugged and flooded Streets
down town submerging our Sanitary manholes.

Reported by (name): Gilles LeBlanc Position: Operator
Phone: 506-533-0054 Date: 12 Aug 2019