

**Annex C1 – Notice of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

|        |   |                           |   |                       |
|--------|---|---------------------------|---|-----------------------|
| Step 1 | [FA s.38 Emergency Notification Agency]         | 1-800-565-1633<br>(voice) | <input checked="" type="checkbox"/> Contacted | <i>Mariana D'Arve</i> |
| Step 2 | [CMP Notification System (Atlantic Catch Data)] | 1-888-477-4245<br>(voice) | <input checked="" type="checkbox"/> Contacted | <i>Cathleen</i>       |

*conf # 2019 08 05 120*

| Step 3                          | To: | Name  | eMail  | OR | Fax          |
|---------------------------------|-----|---|--|----|--------------|
| Environment Canada              |     | MWQM Atlantic                               | shellfish.atlantic@ec.gc.ca  | OR | 902-490-0711 |
| Fisheries and Oceans Canada     |     | CSSP closure – PCCSM Fermeture              | <a href="mailto:Closure-Fermeture@dfo-mpo.gc.ca">Closure-Fermeture@dfo-mpo.gc.ca</a>   | OR | 506-851-2615 |
| Canadian Food Inspection Agency |     |   | <a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>   | OR | 506-777-3867 |
| DELGNB Health NB Health NB      |     | Marc Léger<br>Diane Fury<br>Josée Theriault | <a href="mailto:marc.leger@gnb.ca">marc.leger@gnb.ca</a><br><a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a><br><a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a> | OR | 506-444-4339 |

**ATTENTION: This is to notify you of the following event:**

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Unplanned discharge
- Planned discharge

Source of discharge:

Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18

Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: \_\_\_\_\_

Lift Stations: UV Building

Start of event:  Known  Estimated

Date: Aug 5 2019

Time: 7:04 am to 9:36 am

Flow: \_\_\_\_\_ Units: \_\_\_\_\_  Known  Estimated

Total volume: 140 000 Units: USgal  Known  Estimated

Fecal coliform: \_\_\_\_\_ MPN/100mL  Known  Estimated

Comments: Canada goose hit pwr ~~line~~ and took out 2 phases

Reported by (name): Gilles LeBlanc Position: operator

Phone: 506-533-0054 Date: Aug 5 2019

**Annex C2 – Notice of **END** of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

| Step 1 | To:                             | Name                           | eMail  | OR | Fax          |
|--------|---------------------------------|--------------------------------|--|----|--------------|
|        | Environment Canada              | MWQM Atlantic                  | shellfish.atlantic@ec.gc.ca  | OR | 902-490-0711 |
|        | Fisheries and Oceans Canada     | CSSP closure – PCCSM Fermeture | <a href="mailto:Closure-Fermeture@dfo-mpo.gc.ca">Closure-Fermeture@dfo-mpo.gc.ca</a>                         | OR | 506-851-2615 |
|        | Canadian Food Inspection Agency |                                | <a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a> | OR | 506-777-3867 |
|        | DELGNB                          | Francis LeBlanc                | Francis.LeBlanc@gnb.ca   | OR | 506-856-2374 |

**ATTENTION: This is to notify you the following event has ENDED:**

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Release of Partially-treated wastewater | <input checked="" type="checkbox"/> Unplanned discharge |
| <input type="checkbox"/> Release of Untreated wastewater                    | <input type="checkbox"/> Planned discharge              |

Comments: UV Building 25 Cap-Brulé Road  
Boudreau - Ouest  
Ended 9:36AM Duration: 2 hours + 32 minutes

Reported by (name): Gilles LeBlanc Position: Operator  
 Phone: (506) 532-0054 Date: August 5, 2019