

Annex C1 – **Notice of Wastewater System Discharge** *Loss of UV disinfection*

From: **The Greater Shediac Sewerage Commission Boudreau-Ouest**

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input type="checkbox"/> Contacted
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted

Step 3	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Diane Fury Josée Theriault	marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Loss of UV disinfection (unplanned)*
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: _____
Lift Stations: Cap Breton WWTP

Start of event: Known Estimated

Date: March 30 2020

Time: 4:45pm

Flow: _____ Units: _____ Known Estimated
 Total volume: _____ Units: _____ Known Estimated
 Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Power failure affecting 7,000+ clients in South Eastern NB.

Reported by (name): Joey Frenette Position: General Manager

Phone: 506 533 0039 Date: March 31, 2020

Annex C2 – Notice of **END of Wastewater System Discharge** *Loss of UV disinfection*

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Unplanned discharge
- Planned discharge

Loss of UV disinfection (unplanned)

Comments: Power back "on" at 6:47pm March 30.
≈ 2 hours without UV disinfection

Reported by (name): Joey Frenette Position: General Manager
Phone: 506 533 0039 Date: March 31, 2020