

Annex C1 – **Notice** of Wastewater System Discharge

From: **The Greater Shediac Sewerage Commission Boudreau-Ouest**

Step 1	[FA s.38 Emergency Notification Agency] <i>Barbara Soos</i>	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted
Step 2	[CMP Notification System (Atlantic Catch Data)] <i>2020 07 30 1627</i>	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted <i>During</i>

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: LS #5
Lift Stations: _____

Start of event: Known Estimated

Date: 30 July 2020
Time: 305 pm to 405 pm

Flow: _____ Units: _____ Known Estimated
 Total volume: _____ Units: _____ Known Estimated
 Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Contractor had open main sewer line when Rain Event happened

Reported by (name): Gilles LeBlanc Position: Operator

Phone: 506-533-0054 Date: 30 July 2020

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- | | |
|--|---|
| <input type="checkbox"/> Release of Partially-treated wastewater | <input checked="" type="checkbox"/> Unplanned discharge |
| <input type="checkbox"/> Release of Untreated wastewater | <input type="checkbox"/> Planned discharge |

Diluted

Comments: Open Trench from Contractor Flooded
Trench during Down pour and surcharged
sewer system

Reported by (name): Gilles LeBlond Position: Operator
Phone: 506-533-8016 Date: 30 July 2020