

2020 SCOUDOUK WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
12-Feb	145	98	6	5	8.90	2.14
20-May	163	114	13	12	3.30	1.40
09-Sep	227	224	6	5	2.00	2.82
04-Nov	81	64	9	10	29.00	1.91
Average	154	125	9	8		

- Effluent standards are: as per DELGNB CofA S-3169.

CBOD₅ and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.) - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.