

Annex C1 – Notice of Wastewater System Discharge

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted 1:28pm
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted 1:31pm

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfm-mpo.gc.ca	OR	506-851-2615
Canadian Food Inspection Agency			NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater *diluted*
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: No.3 - 38 Doute St, Shediac
Lift Stations: _____

Start of event: Known Estimated

Date: March 29 '21

Time: 1:00pm (on-going)

Flow: ≈ 10 to 20 Units: 1.5gpm Known Estimated
 Total volume: _____ Units: _____ Known Estimated
 Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Rain + snow melt - Infiltration

Reported by (name): Joey Frenette Position: Director, operations

Phone: 506 533 0039 Date: 29 Mars '21

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfm-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- | | |
|--|--|
| <input type="checkbox"/> Release of Partially-treated wastewater | <input type="checkbox"/> Unplanned discharge |
| <input checked="" type="checkbox"/> Release of Untreated wastewater <i>diluted</i> | <input type="checkbox"/> Planned discharge |

Comments: Diluted untreated wastewater overflow - LS#3 Dock St
Started March 29, 2021, @ 1pm
Ended March 29, 2021 @ 2:05pm => 1hr 5min

Reported by (name): Joey Frenette

Position: Director, operations

Phone: 506 533 0039

Date: March 30, 2021