

Step #1 - called @ 14:31
 Step #2 - called @ 14:39

1 506 533-0425

Annex C1 - Notice of Wastewater System Discharge

Conf #
 2020 02 13 1440

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted
Step 2	[CMP Notification System (Atlantic Catch Data)]	1-888-477-4245 (voice)	<input checked="" type="checkbox"/> Contacted

Step 3	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure - PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Diane Fury Josée Theriault	marc.leger@gnb.ca diane.fury@gnb.ca josee.theriault@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you of the following event:

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: #5 - 150 Pleasant St, Shediac
 Lift Stations: _____

Start of event: Known Estimated

Date: Feb 13, 2021
 Time: 9:00 am - 11:30 am

Flow: _____ Units: Known Estimated
 Total volume: 5000 lts. Units: Known Estimated
 Fecal coliform: _____ MPN/100mL Known Estimated

Comments: Force Main Break in Road, Possible water Main Break as well, Truck pumping wet well From 11:30 am on.

Reported by (name): Cory Babin eau Position: Waste Water operator
 Phone: 1 506 533-0425 Date: Feb 13, 2021

Annex C2 – Notice of **END of Wastewater System Discharge**

From: The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	Closure-Fermeture@dfo-mpo.gc.ca	OR	506-851-2615
	Canadian Food Inspection Agency		NB_CSSP_Coordination_PCCSM@inspection.gc.ca	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	Marc.Leger@gnb.ca josee.theriault@gnb.ca diane.fury@gnb.ca	OR	506-444-4339

ATTENTION: This is to notify you the following event has ENDED:

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Unplanned discharge
- Planned discharge

Comments: Ended 11:30am Feb 13 '21

Reported by (name): Joey Frenette Position: Director, Operations

Phone: 1-506-533-0039 Date: Feb 16 '21