

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2021-05-18-02
Address:	25 Cap Brule Road	Reported By:	Joey frenette
		Initial Report Date/Time:	2021-05-18 6:03:11 PM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC. - Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456 - Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2021-05-18 5:24:00 PM	<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event	
Preliminary Overflow Estimate (m3/s)	0		
Source of Discharge: LS 24 - Cap Brulé Rd (Zone B)			
Affected Zone(s):			
Comments:			
Reason for Reporting:			
<input type="checkbox"/> Release of Untreated Wastewater		<input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail)	
<input type="checkbox"/> Release of Partially Treated Wastewater		<input type="checkbox"/> Interruption of UV Treatment above closure thresholds	
<input type="checkbox"/> Release of Diluted Untreated Wastewater		<input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Choliform, etc) (No Public Email)	
<input checked="" type="checkbox"/> Loss of Disinfection		<input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds	
<input type="checkbox"/> Other circumstances not listed above		<input type="checkbox"/> Will this other reason have a marine impact?	
		<input type="checkbox"/> Yes <input type="checkbox"/> No	
Description of other circumstances			
Comments:			
General Comments:			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s)	0	Estimated Total Overflow (m3)		

Describe the circumstances that led to this event:

Power failure affecting thousands of clients in the area

Describe the actions taken to resolve the problem that led to this event:

Describe the actions that will be taken to ensure this problem does not occur again:

Upgrading of wwtp

Start of Event (Date/Time):	2021-05-18 5:24:00 PM
Start of Event Report Submitted by:	Joey frenette
End of Event (Date/Time):	2021-05-18 6:58:00 PM
End of Event Report Submitted by:	joey frenette
Duration of the Event (hours):	0.566666666666667 1h 24min

This version of the report was drafted on **2021-05-18** at **7:14 PM**