

## 2021 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD <sub>5</sub>	SS	CBOD <sub>5</sub>	SS	TKN	TP
02-Mar	63	87	6	5	12.70	3.00
28-Apr	81	118	6	5	1.90	1.00
14-Sep	208	149	6	5	1.50	0.85
09-Nov	274	180	6	5	1.50	1.90
Average	157	134	6	5		

- Effluent standards are: as per DELGNB CofA S-3169.

**CBOD<sub>5</sub> and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.)** - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD<sub>5</sub>**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.