

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-18-01
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-18 6:23:02 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 12:00:00 AM	<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event	
Preliminary Overflow Estimate (m³/s)	4.390m ³ /s 20		
<p>Source of Discharge: LS 2 - Main St (Zone A)</p> <p>Affected Zone(s): Shediac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; flex-wrap: wrap;"> <div style="width: 50%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 50%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Choliform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="display: flex; justify-content: flex-end; margin-top: 10px;"> <input type="checkbox"/> Yes <input type="checkbox"/> No </div> <p>Description of other circumstances</p> <p>Comments: Weather warnings in place, heavy rain and wind event</p>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m³/s)	30		Estimated Total Overflow (m3)	

Describe the circumstances that led to this event:

Weather, heavy rains and wind with warm temperatures melting snow

Describe the actions taken to resolve the problem that led to this event:

Check equipment for proper function

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 12:00:00 AM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	
End of Event Report Submitted by:	
Duration of the Event (hours):	

This version of the report was drafted on 2022-02-18 at 6:23 AM

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-18-01
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-18 6:23:02 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 1:00:00 AM	<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event	
Preliminary Overflow Estimate (m3/s)	2.0		
Source of Discharge: LS 2 - Main St (Zone A)			
Affected Zone(s):			
Comments:			
Reason for Reporting:			
<input type="checkbox"/> Release of Untreated Wastewater		<input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail)	
<input type="checkbox"/> Release of Partially Treated Wastewater		<input type="checkbox"/> Interruption of UV Treatment above closure thresholds	
<input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater		<input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email)	
<input type="checkbox"/> Loss of Disinfection		<input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds	
<input type="checkbox"/> Other circumstances not listed above		Will this other reason have a marine impact? <input type="checkbox"/> Yes <input type="checkbox"/> No 	
Description of other circumstances			
Comments: Weather warnings in place, heavy rain and wind event			
General Comments:			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s) <i>45 gpm</i>	<i>20</i>	Estimated Total Overflow (m3)		

Describe the circumstances that led to this event:

Weather, heavy rains and wind with warm temperatures melting snow

Describe the actions taken to resolve the problem that led to this event:

Check equipment for proper function

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 1:00:00 AM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	2022-02-19 4:00:00 AM
End of Event Report Submitted by:	Cory Babineau
Duration of the Event (hours):	27

This version of the report was drafted on **2022-02-19** at **7:58 AM**

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-19-01
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-19 8:04:00 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 6:00:00 AM	<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event	
Preliminary Overflow Estimate (m³/s)	0.01 20		
<p>Source of Discharge: LS 3 - Dock St (Zone A)</p> <p>Affected Zone(s): Shediac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; flex-wrap: wrap;"> <div style="width: 50%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 50%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="display: flex; justify-content: flex-end; margin-top: 10px;"> <input type="checkbox"/> Yes <input type="checkbox"/> No </div> <p>Description of other circumstances</p> <p>Comments:</p>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s) 45 gpm	0.01 20		Estimated Total Overflow (m3)	

Describe the circumstances that led to this event:

weather event, heavy rain with warm temperatures and melting snow

Describe the actions taken to resolve the problem that led to this event:

ensure equipment running to full potential

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 6:00:00 AM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	
End of Event Report Submitted by:	
Duration of the Event (hours):	

This version of the report was drafted on

at

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-19-01
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-19 8:04:00 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 6:00:00 AM		<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event
Preliminary Overflow Estimate (m³/s)	0.01 30 <i>45 ppm</i>		
<p>Source of Discharge: LS 3 - Dock St (Zone A)</p> <p>Affected Zone(s): Shédiac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 45%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div> <input type="checkbox"/> Will this other reason have a marine impact? </div> <div> <input type="checkbox"/> Yes <input type="checkbox"/> No </div> </div> <p>Description of other circumstances</p> <p>Comments:</p>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s)	0.01 20	Estimated Total Overflow (m3)		

Describe the circumstances that led to this event:

weather event, heavy rain with warm temperatures and melting snow

Describe the actions taken to resolve the problem that led to this event:

ensure equipment running to full potential

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 6:00:00 AM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	2022-02-19 7:00:00 AM
End of Event Report Submitted by:	Cory Babineau
Duration of the Event (hours):	25

This version of the report was drafted on **2022-02-19** at **8:07 AM**

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-19-02
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-19 8:11:56 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 7:00:00 AM		<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event
Preliminary Overflow Estimate (m³/s)	0.01 30 <i>1.54pm</i>		
<p>Source of Discharge: LS 4 - Hamilton St (Zone A)</p> <p>Affected Zone(s): Shediac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 45%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div style="width: 45%;"> <p>Description of other circumstances</p> <p>Comments:</p> </div> <div style="width: 45%;"> <p>Will this other reason have a marine impact? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> </div> </div>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m ³ /s) 427gpm	0.01 30		Estimated Total Overflow (m ³)	

Describe the circumstances that led to this event:

weather event, heavy rain with warm temperatures increased snow melting

Describe the actions taken to resolve the problem that led to this event:

monitor equipment for maximum operations

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 7:00:00 AM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	
End of Event Report Submitted by:	
Duration of the Event (hours):	

This version of the report was drafted on

at

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-19-02
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-19 8:11:56 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 7:00:00 AM	<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event	
Preliminary Overflow Estimate (m³/s)	0.01 30		
<p>Source of Discharge: LS 4 - Hamilton St (Zone A)</p> <p>Affected Zone(s): Shédiac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; flex-wrap: wrap;"> <div style="width: 50%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 50%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="margin-top: 10px;"> <input type="checkbox"/> Will this other reason have a marine impact? <input type="checkbox"/> Yes <input type="checkbox"/> No </div> <p>Description of other circumstances</p> <p>Comments:</p>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s) <i>145 gpm</i>	0.01 <i>30</i>	Estimated Total Overflow (m3)		

Describe the circumstances that led to this event:

weather event, heavy rain with warm temperatures increased snow melting

Describe the actions taken to resolve the problem that led to this event:

monitor equipment for maximum operations

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 7:00:00 AM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	2022-02-19 7:00:00 AM
End of Event Report Submitted by:	Cory Babineau
Duration of the Event (hours):	24

This version of the report was drafted on 2022-02-19 at 8:15 AM

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-19-03
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-19 8:18:33 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 1:00:00 PM		<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event
Preliminary Overflow Estimate (m³/s)	0.01 20		
<p>Source of Discharge: LS 5 - Pleasant St (Zone A)</p> <p>Affected Zone(s): Shediac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 45%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div style="width: 45%;"> <p>Description of other circumstances</p> <p>Comments:</p> </div> <div style="width: 45%;"> <p>Will this other reason have a marine impact? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> </div> </div>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s) 125 gpm	0.01 30		Estimated Total Overflow (m3)	

Describe the circumstances that led to this event:

weather event, heavy rain, warm temperatures resulting in melting snow

Describe the actions taken to resolve the problem that led to this event:

ensure equipment running properly

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 1:00:00 PM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	
End of Event Report Submitted by:	
Duration of the Event (hours):	

This version of the report was drafted on

at

REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
Facility Name:	GSSC - Cap-Brulé	Event ID:	CBB-2022-02-19-03
Address:	25 Cap Brule Road	Reported By:	Cory Babineau
		Initial Report Date/Time:	2022-02-19 8:18:33 AM
<p>Please ensure that you are aware of all regulatory reporting requirements in your area. In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
Start of Event (Date/Time)	2022-02-18 1:00:00 PM		<input checked="" type="checkbox"/> Unplanned Discharge Event <input type="checkbox"/> Planned Discharge Event
Preliminary Overflow Estimate (m³/s)	0.01 20 <i>11:54pm</i>		
<p>Source of Discharge: LS 5 - Pleasant St (Zone A)</p> <p>Affected Zone(s): Shediac Bay - Zone A</p> <p>Comments:</p>			
<p>Reason for Reporting:</p> <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <input type="checkbox"/> Release of Untreated Wastewater <input type="checkbox"/> Release of Partially Treated Wastewater <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater <input type="checkbox"/> Loss of Disinfection <input type="checkbox"/> Other circumstances not listed above </div> <div style="width: 45%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail) <input type="checkbox"/> Interruption of UV Treatment above closure thresholds <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Cholorform, etc) (No Public Email) <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div> <input type="checkbox"/> Will this other reason have a marine impact? </div> <div> <input type="checkbox"/> Yes <input type="checkbox"/> No </div> </div> <p>Description of other circumstances</p> <p>Comments:</p>			
<p>General Comments:</p>			

SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s) 185 gpm	0.01 20		Estimated Total Overflow (m3)	

Describe the circumstances that led to this event:

weather event, heavy rain, warm temperatures resulting in melting snow

Describe the actions taken to resolve the problem that led to this event:

ensure equipment running properly

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-02-18 1:00:00 PM
Start of Event Report Submitted by:	Cory Babineau
End of Event (Date/Time):	2022-02-18 4:00:00 PM
End of Event Report Submitted by:	Cory Babineau
Duration of the Event (hours):	3

This version of the report was drafted on 2022-02-19 at 8:21 AM