

*loss of UV disinfection*

**Annex C1 – Notice of Wastewater System Discharge**

**From: The Greater Shediac Sewerage Commission Boudreau-Ouest**

<b>Step 1</b>	[FA s.38 Emergency Notification Agency]	1-800-565-1633 (voice)	<input checked="" type="checkbox"/> Contacted
<b>Step 2</b>	[CMP Notification System (Atlantic Catch Data)] <i>* tried to report on line; wasn't working</i>	1-888-477-4245 (voice)	<input type="checkbox"/> Contacted

Step 3	To:	Name	eMail	OR	Fax
Environment Canada		MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
Fisheries and Oceans Canada		CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@df-mpo.gc.ca">Closure-Fermeture@df-mpo.gc.ca</a>	OR	506-851-2615
Canadian Food Inspection Agency			<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
DELGNB Health NB Health NB		Marc Léger Diane Fury Josée Theriault	<a href="mailto:marc.leger@gnb.ca">marc.leger@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you of the following event:**

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Loss of UV disinfection
- Unplanned discharge
- Planned discharge

Source of discharge:

- Zone A: 1, 2, 3, 4, 5, 6, 7, 8, 11, 13, 14, 15, 16, 17, 18
- Zone B: 9, 10, 12, 19, 20, 24

Lift Stations: \_\_\_\_\_  
Lift Stations: #24 - CapBreule WWTTP

Start of event:  Known       Estimated

Date: Aug 10' 22  
Time: 6:36 pm

Flow: \_\_\_\_\_ Units: \_\_\_\_\_  Known       Estimated  
 Total volume: \_\_\_\_\_ Units: \_\_\_\_\_  Known       Estimated  
 Fecal coliform: \_\_\_\_\_ MPN/100mL       Known       Estimated

Comments: Major power failure - over 50,000+ clients in South Eastern, NB  
Wastewater released to shediac Bay was treated, but not disinfected!

Reported by (name): Joey Frenette      Position: Director, operations

Phone: (506) 533-0039      Date: Aug 12' 22

Annex C2 – Notice of **END** of loss of UV disinfection ~~Wastewater System Discharge~~

**From:** The Greater Shediac Sewerage Commission Boudreau-Ouest

Step 1	To:	Name	eMail	OR	Fax
	Environment Canada	MWQM Atlantic	shellfish.atlantic@ec.gc.ca	OR	902-490-0711
	Fisheries and Oceans Canada	CSSP closure – PCCSM Fermeture	<a href="mailto:Closure-Fermeture@dfo-mpo.gc.ca">Closure-Fermeture@dfo-mpo.gc.ca</a>	OR	506-851-2615
	Canadian Food Inspection Agency		<a href="mailto:NB_CSSP_Coordination_PCCSM@inspection.gc.ca">NB_CSSP_Coordination_PCCSM@inspection.gc.ca</a>	OR	506-777-3867
	DELGNB Health NB Health NB	Marc Léger Josée Theriault Diane Fury	<a href="mailto:Marc.Leger@gnb.ca">Marc.Leger@gnb.ca</a> <a href="mailto:josee.theriault@gnb.ca">josee.theriault@gnb.ca</a> <a href="mailto:diane.fury@gnb.ca">diane.fury@gnb.ca</a>	OR	506-444-4339

**ATTENTION: This is to notify you the following event has ENDED:**

- Release of Partially-treated wastewater
- Release of Untreated wastewater
- Loss of UV disinfection
- Unplanned discharge
- Planned discharge

Comments: Power returned 11:15pm. Loss of disinfection at  
Cup Brulé WWT from 8:36pm to 11:15pm, Aug 10'22  
≈ 2h40 min ; ≈ 275,000 us gallons

Reported by (name): Joey Frenette Position: Director, Operations  
 Phone: (506) 533-0039 Date: Aug 12'22