

## REPORT: Wastewater Treatment Plant Event

SECTION 1: EVENT LOCATION AND CONTACT DETAILS			
<b>Facility Name:</b>	GSSC - Cap-Brulé	<b>Event ID:</b>	CBB-2022-08-14-01
<b>Address:</b>	25 Cap Brule Road	<b>Reported By:</b>	joey frenette
		<b>Initial Report Date/Time:</b>	2022-08-14 11:07:49 AM
<p><b>Please ensure that you are aware of all regulatory reporting requirements in your area.</b> In addition to using the Wastewater Treatment Plant (WWTP) Reporting Tool, operators may be required to report a spill as soon as possible to:</p> <p>→ The National Environmental Emergency Centre (NEEC) or EMBC.</p> <p>- Phone: Atlantic: 1-800-565-1633, Quebec: 1-866-283-2333, Pacific: 1-800-663-3456</p> <p>- Email: Atlantic: Ec.FA-LP-Atl.ec@canada.ca, Quebec: ec.cnue-neec.ec@canada.ca, Pacific: Ec.FA-LP-Pac.ec@canada.ca</p> <p>→ Canadian Coast Guard or provincial authorities, as appropriate.</p>			
SECTION 2: DESCRIPTION OF THE EVENT			
<b>Start of Event (Date/Time)</b>	2022-08-14 10:34:00 AM	<input checked="" type="checkbox"/> Unplanned Discharge Event  <input type="checkbox"/> Planned Discharge Event	
<b>Preliminary Overflow Estimate (m3/s)</b>	0.00189		
<p><b>Source of Discharge:</b> LS 2 - Main St (Zone A)</p> <p><b>Affected Zone(s):</b></p> <p><b>Comments:</b></p>			
<p><b>Reason for Reporting:</b></p> <div style="display: flex; flex-wrap: wrap;"> <div style="width: 50%;"> <input type="checkbox"/> Release of Untreated Wastewater  <input type="checkbox"/> Release of Partially Treated Wastewater  <input checked="" type="checkbox"/> Release of Diluted Untreated Wastewater  <input type="checkbox"/> Loss of Disinfection  <input type="checkbox"/> Other circumstances not listed above         </div> <div style="width: 50%;"> <input type="checkbox"/> Interruption of UV Treatment below closure thresholds (No public e-mail)  <input type="checkbox"/> Interruption of UV Treatment above closure thresholds  <input type="checkbox"/> Non-compliant Water Sample (High Suspended Solids, BOD, Choliform, etc) (No Public Email)  <input type="checkbox"/> Non-compliant Water Sample exceeding closure thresholds         </div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div> <p><b>Description of other circumstances</b></p> <p><b>Comments:</b></p> </div> <div> <p>Will this other reason have a marine impact?</p> <div style="text-align: right;"> <input type="checkbox"/> Yes  <input type="checkbox"/> No         </div> </div> </div>			
<p><b>General Comments:</b></p>			

### SECTION 3: EVENT DETAILS

(Please note that all values are estimated)

BOD (mg/L)	FC (/100 ml)	Chlorine (mg/L)	SS (mg/L)	pH
Estimated Flow Rate (m3/s)	0.00189	Estimated Total Overflow (m3)		

Describe the circumstances that led to this event:

Heavy rainfall

Describe the actions taken to resolve the problem that led to this event:

On going replacement of collection system + I&I monitoring

Describe the actions that will be taken to ensure this problem does not occur again:

Start of Event (Date/Time):	2022-08-14 10:34:00 AM
Start of Event Report Submitted by:	joey frenette
End of Event (Date/Time):	2022-08-14 5:30:00 PM
End of Event Report Submitted by:	joey frenette
Duration of the Event (hours):	6.933333333333333

This version of the report was drafted on 2022-08-14 at 5:53 PM