

## 2022 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD <sub>5</sub>	SS	CBOD <sub>5</sub>	SS	TKN	TP
02-Feb	187	131	< 6	< 5	13.00	2.60
08-Jun	230	197	< 6	< 5	1.70	1.74
17-Aug	168	104	< 6	14	2.10	3.19
08-Oct	152	105	< 6	< 5	2.90	2.74
Average	184	134	<6	7		

- Effluent standards are: as per DELGNB CofA S-3169.

**CBOD<sub>5</sub> and SS - annual average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.)** - (as per WSER)

- Legend: **SS**: Suspended Solids, **CBOD<sub>5</sub>**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.