

## 2024 Cap Brulé WWTP - Lab Results

[illegible]

- Effluent standards are: as per DELGNB CofA S-3281

**CBOD<sub>5</sub> and SS - quaterly average ≤ 25mg/l (SS exception >25mg/l, Jul-Oct.)**

**E.Coli  $\leq 200$  MPN/100ml - From May 1st to October 31st**

**E.Coli ≤ 1000 MPN/100ml - From November 1st to April 30th (effective April 30, 2019)**

- Legend: **SS**: Suspended Solids, **CBOD<sub>5</sub>**: Carbonaceous Biochemical Oxygen Demand, **TAN**: Total Ammonia Nitrogen,

These analyses are conducted by RPC Laboratories - Moncton

Enterococci results do not have to be reported