

2024 SCOUDOUC WWTP - Lab Results

Date	Influent		Effluent			
	CBOD ₅	SS	CBOD ₅	SS	TKN	TP
16-Jan	136	88	6	5	8.10	1.37
07-May	99	63	6	8	4.00	2.08
10-Sep	262	170	6	5	1.40	3.84
19-Nov	98	79	6	5	9.40	3.01
Average	149	100	6	6		

- Effluent standards: as per DELGNB CofA S-3169 (until Mar 12, 2024), then CofA S-3596 (starting March 13, 2024), then CofA S-3853 (starting June 5, 2024)

CBOD₅ and SS - annual average ≤ 25mg/l (SS exception >25mg/l, May to November)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.