

## 2025 SCOUDOUK WWTP - Lab Results

Date	Influent		Effluent			
	CBOD <sub>5</sub>	SS	CBOD <sub>5</sub>	SS	TKN	TP
04-Feb	172	129	6	5	15.00	2.98
29-Apr	65	47	6	6	4.30	1.44
19-Aug	294	376	6	5	2.10	3.17
28-Oct	236	219	6	7	2.10	2.25
Average	192	193	6	6		

- Effluent standards: as per DELGNB CofA S-3169 (until Mar 12, 2024), then CofA S-3596 (starting March 13, 2024), then CofA S-3853 (starting June 5, 2024)

**CBOD<sub>5</sub> and SS - annual average ≤ 25mg/l (SS exception >25mg/l, May to November)**

- Legend: **SS**: Suspended Solids, **CBOD<sub>5</sub>**: Carbonaceous Biochemical Oxygen Demand, **TKN**: Total Kjeldahl Nitrogen, **TP**: Total Phosphorus.