

2026 Cap Brulé WWTP - Lab Results

[illegible]

--	--

- Effluent standards are: as per DELGNB CofA S-3904

CBOD₅ and SS - quarterly average ≤ 25mg/l (SS exception >25mg/l, May to November)

E.Coli $\leq$ 200 MPN/100ml - From May 1st to October 31st

E.Coli From November 1st to April 30th - Not required to disinfect (effective August 9, 2024)

- Legend: **SS**: Suspended Solids, **CBOD₅**: Carbonaceous Biochemical Oxygen Demand, **TAN**: Total Ammonia Nitrogen.

These analyses are conducted by RPC Laboratories - Moncton

Enterococci results do not have to be reported